

City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

## **INSPECTION REPORT**

Date of Inspection:	Sep 19, 2023	Inspection Result:	FAILED
Permit Number: Property Address:	PRCTI20221460 3811 9TH ST SW, PUYAL	LUP, WA 98373;	
Contractor:	ROYAL PINNACLE ENTERPRISES INC 2329 SOUTH M ST TACOMA, WA		
To construct.	98405 Interior remodel of exist	ing restaurant into a new	v restaurant ~ SALLID
To construct.	Interior remodel of existing restaurant into a new restaurant ~ SALUD BAR & GRILL * REVISION (1) - 4/14/2023 - HEADER CLARIFICATION &		
	REARRANGEMENT OF KITCHEN APPLIANCES * REVISON (2) 7/25/2023 -		
	HVAC LOCATION AND A	ASSOCIATED WORK	

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

## Comments:

## Corrections:

- 1 1 ; complete all exterior caulking as discussed with Brian.
  - 2 ; complete all door sweeps at exterior doors.
  - 3 ; complete accessible signage as both restrooms .
  - 4 ; fix plumbing leak at hammer arrestors at dishwasher and icemaker.
  - 5 ; provide 1" airgap at floor sink next to icemaker.
  - 6 ; complete all sink drains as per code as discussed with Brian.
  - 7 ; complete exit door at exterior storage area.
  - 8 ; paint gas pipe on roof.
  - 9; seal doghouse penetration at mechanical on roof.
  - 10 ; remove abandoned gas pipe on roof.
  - 11; complete accessible table at outdoor patio area.
  - 12 ; complete ceiling tile at mechanical room.
  - 13 ; complete mechanical above kitchen ceiling.
  - 14 ; remove debris from roof prior to final.
  - 15 ; complete panic hardware at exit doors as per code.



City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

Sincerely,

King

Shannon King Building Inspector 2 ShannonK@PuyallupWA.gov (253) 840-6684