



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Sep 19, 2023

Inspection Result: **FAILED**

Permit Number: PRCTI20221460

Property Address: 3811 9TH ST SW, PUYALLUP, WA 98373;

Contractor: ROYAL PINNACLE ENTERPRISES INC 2329 SOUTH M ST TACOMA, WA 98405

To construct: Interior remodel of existing restaurant into a new restaurant ~ SALUD BAR & GRILL * REVISION (1) - 4/14/2023 - HEADER CLARIFICATION & REARRANGEMENT OF KITCHEN APPLIANCES * REVISION (2) 7/25/2023 - HVAC LOCATION AND ASSOCIATED WORK

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1 ; complete all exterior caulking as discussed with Brian.
- 2 ; complete all door sweeps at exterior doors.
- 3 ; complete accessible signage as both restrooms .
- 4 ; fix plumbing leak at hammer arrestors at dishwasher and icemaker.
- 5 ; provide 1" airgap at floor sink next to icemaker.
- 6 ; complete all sink drains as per code as discussed with Brian.
- 7 ; complete exit door at exterior storage area.
- 8 ; paint gas pipe on roof.
- 9 ; seal doghouse penetration at mechanical on roof.
- 10 ; remove abandoned gas pipe on roof.
- 11 ; complete accessible table at outdoor patio area.
- 12 ; complete ceiling tile at mechanical room.
- 13 ; complete mechanical above kitchen ceiling.
- 14 ; remove debris from roof prior to final.
- 15 ; complete panic hardware at exit doors as per code



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Sincerely,

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684