



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Sep 21, 2023

Inspection Result: **PARTIAL PASS**

Permit Number: PRCTI20221793

Property Address: 3500 S MERIDIAN, Unit: 930, PUYALLUP, WA 98373;

Contractor: WASHINGTON PATRIOT CONST LLC 10421 BURNHAM DR SUITE NW
GIG HARBOR, WA 98332

To construct: Construction of a swim school including the pool in the former Sears
store located in the South Hill Mall ~ GOLDFISH SWIM SCHOOL

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 2 1 ; complete urinal 17" max. a.f.f. in restroom as per City approved plans.
- 2; remove all construction debris from roof.
- 3 ; paint all new gas pipe on roof and next to gas meter.
- 4 ; T.C.O. approved for 10 working days from 9/21/2023

Sincerely,

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

(253) 840-6684