



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Sep 27, 2023

**Inspection Result:** **FAILED**

**Permit Number:** B-20-0078

**Property Address:** 1515 S MERIDIAN, PUYALLUP, WA 98371;

**Contractor:** BALDWIN GENERAL CONTRACTING PO BOX 686, 0876 ALBANY, OR 93721

**To construct:** HAMPTON INN ADDITION & PARKING BELOW E-20-0052  
PRGR20230876

On this day we have inspected your construction for **Plumbing Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 1. under slab plumbing inspection  
2. storm line, sewer line, parking garage drains approved as marked up on sheet P-200 of city approved plans  
3. use clean backfill as discussed with plumber
- 2 1 ; provide as built plumbing plan approval from mechanical engineer for changes to below slab plumbing.  
2 ; test failed on below slab plumbing. ( no 10' head test at time of inspection)

Sincerely,

Shannon King



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

Building Inspector 2

[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)

(253) 840-6684