



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Sep 28, 2023

Inspection Result: **PARTIAL PASS**

Permit Number: PRFUP20230021

Property Address: 401 RIVER RD, PUYALLUP, WA 98371;

Contractor: PSE - INFRASOURCE 3130 S 38TH ST TACOMA, WA 98409

To construct: PERMIT EXT TO 10/18/2023 - Relocate approx. 490' of 2" gas main for City Storm Project - Most of the work is on 4th St NW. With five 4x4 cuts, one 4x7, and one 4x10 cut in hard surface right of way. CIP ENGINEER Ryan Rutkosky/CIP INSPECTOR Ron Johnson

On this day we have inspected your construction for **Close All Restoration Complete Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: AA Asphalt finished all three G&O's today. The largest one that was 1/2 in the drive lane and through multiple parking stalls was too thin for a 1.5" to 2" G&O. The bottom lift was moving and pealed up in some areas and in others it was either rock or dirt. So they dropped to a 3" G&O in this area only.

Note: See corrections below for final acceptance.

Schedule a "Close All Restoration Complete" for the same day that the stripping is being installed.

Corrections:

1. - White stripe multiple parking stalls to match other around them.
2. - Yellow stripe CL & gore where grinder and/or sealer was installed, along with dirty tack tires crossing.

Sincerely,



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Jason Little

Engineering Tech IV

JLittle@PuyallupWA.gov

(253) 435-3636