



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Sep 29, 2023 **Inspection Result:** **PARTIAL PASS**

Permit Number: B-20-0180

Property Address: 3601 9TH ST SW, PUYALLUP, WA 98373;

Contractor: THARALDSON HOSPITALITY DEV LLC 4520 36TH AVE S FARGO, ND
58104 Roger Olson 4520 36th ave s fargo, ND 58104 (701) 850-9953

To construct: HOMEWOOD SUITES SOUTH HILL MALL MOTEL *FEE DEFERRAL-SWR*
REVISION (1) 6/8/2023 - VALUE ENGINEER FOOTINGS AND ADD
PERIMETER DRAINTILE

On this day we have inspected your construction for **Plumbing Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1. this was a under slab plumbing inspection
2.rain drain, sump pump at elevator pit approved as marked on page P-202B
3. 4" deep sewer approved as marked up on page P-202A
4. 4" water service on air test at 80 PSI approved as marked up on page P-201B
- 2 1. this was under slab plumbing inspection
2. contractor to provide approved as-built of all plumbing changes from engineer of record at time of final under slab plumbing inspection as discussed with contractor
3.partial approval of rain drain as marked on P-202-A of city approved plans
4.partial approval on deep sewer as marked on pages P-202-A and P-202-B of city approved plans
5.partial approval of grease interceptor on interior of building going into sewer as marked on city P-202-A of city approved plans

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Kevin Spruell

Building Inspector I

KSpruell@PuyallupWA.gov

(253) 841-5590