



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Oct 04, 2023

Inspection Result: **PARTIAL PASS**

Permit Number: PRCTI20230247

Property Address: 733 RIVER RD, PUYALLUP, WA 98371;

Contractor: RAAB & SON'S 12630 SW CEMTERY RD VASHON ISLAND, WA 98070

To construct: TI PREVIOUS EXISTING BLDG OF DMV ~ ENTERPRISE RENT-A-CAR

On this day we have inspected your construction for **Plumbing Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1. no lines or floor drains installed at time of inspection that go in to grease interceptor
2. provide AS-built approval of under ground plumbing from EOR at time of slab inspection
3. DWV under slab approved pending as-built approval from EOR

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590