### **Engineering Division**

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

#### INSPECTION REPORT

**Date of Inspection:** Oct 04, 2023 **Inspection Result: PARTIAL PASS** 

Permit Number: PRFUP20231150

**Property Address:** 4010 10TH ST SE, PUYALLUP, WA 98374;

Contractor: FRUITLAND MUTUAL WATER PO BOX 73759 PUYALLUP, WA 98373-

0759

**To construct:** Installing new water service for Copperberry Condominiums.

On this day we have inspected your construction for Comment Engineering Div Inspection and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** Spoke with Fruitland about restoration.

Cold patch on west walk was cleaned up and looks good.

Note: See corrections below! Schedule inspection for same day of restoration. Need to verify no other chips, cracks, or lifting, depths of rock, asphalt, and concrete.

#### **Corrections:**

- 1 1. Okay to "T" patch with 1-2' over cut on both sides (north and south) of ditch line entire length (east and west) on 10th.
  - 2. G&O east side of 10th 1/2 lane 18' wide (9' from center of ditch each way). GC will take care of 1/2 street G&O across frontage on west side of 10th.
  - 3. Remove and replace 8-10 LF of cracked sidewalk on east side of 10th. (Areas marked in white)
  - 4. Remove and replace 24-30 LF of lifted, chipped, and cracked C&G on east side of 10th. (Areas marked in white)
  - 5. Pour back what was removed for water main installation.
  - 6. Dress up landscape as necessary to restore sidewalk on east side of 10th.

Note: Patch for ditch line may not be same day as G&O!

Note: No exception for added chips, cracks, or lifting of existing concrete.




## City of Puyallup

# **Engineering Division**

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

Sincerely,



Jason Little Engineering Tech IV JLittle@PuyallupWA.gov (253) 435-3636