



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Oct 04, 2023 **Inspection Result:** **FAILED**

Permit Number: B-20-0078

Property Address: 1515 S MERIDIAN, PUYALLUP, WA 98371;

Contractor: BALDWIN GENERAL CONTRACTING PO BOX 686, 0876 ALBANY, OR
93721

To construct: HAMPTON INN ADDITION & PARKING BELOW E-20-0052
PRGR20230876

On this day we have inspected your construction for **Foundation/Rebar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1 ; no foundation walls ready for inspection. (footings only)
- 2 1 ; cancel per contractor - not ready
- 3 1.10/4/2023 inspection date 1. provide inspection reports from special inspection as well as geotech of record approval for the reports for soil bearing compaction for footing being poured per city approved S sheets
1. DO NOT POUR

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590