

City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection:	Oct 06, 2023	Inspection Result:	PART	IAL PASS
Permit Number: Property Address:	B-20-0078 1515 S MERIDIAN, PUYA	LLUP, WA 98371;		
Contractor:	BALDWIN GENERAL CO 93721	NTRACTING PO BOX 686	6, 0876	ALBANY, OR
To construct:	HAMPTON INN ADDITIC PRGR20230876	DN & PARKING BELOW E	E-20-00	52

On this day we have inspected your construction for **Foundation/Rebar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1. footings approved to pour per special inspections

Corrections:

- 1 1; no foundation walls ready for inspection. (footings only)
- 2 1; cancel per contractor not ready

Sincerely,

Kevin Spruell Building Inspector I KSpruell@PuyallupWA.gov (253) 841-5590