


Section 2902.3.1 of the 2018 IBC Access to restroom: The route to the public toilet facilities required by Section 2902.3 shall not pass through kitchens, food preparation areas, unpackaged food storage areas, storage rooms or closets. Access to the required facilities shall be from within the building or from the exterior of the building. Access to toilets serving multiple tenants shall be through a common use area and not through an area controlled by a tenant. All routes shall comply with the accessibility requirements of this code. The public shall have access to the required toilet facilities at all times that the building is occupied.

OFFICE	BATHROOM	BATHROOM
--------	----------	----------

**City of Puyallup**  
**Building**  
**ACCEPTED**

JMontgomery  
10/10/2023  
2:03:43 PM

The seal of the City of Puyallup, State of Washington, is circular. It features a stylized landscape with a blue river flowing through a green forest of evergreen trees. In the background, there are white, snow-capped mountains. The words "CITY OF PUYALLUP" are written in a circle around the top, and "STATE OF WASHINGTON" is written around the bottom.

FULL SIZED LEDGIBLE COLOR  
PLANS ARE REQUIRED TO BE  
PROVIDED BY THE PERMITTEE ON  
SITE FOR ALL INSPECTIONS  
(MIN. PLAN SIZE 24" X 36")