



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Oct 11, 2023

**Inspection Result:** **FAILED**

**Permit Number:** PRCTI20230656

**Property Address:** 1450 5TH ST SE, PUYALLUP, WA 98372;

**Contractor:** ABBOTT CONSTRUCTION 3408 1ST AVENUE SOUTH SEATTLE, WA  
98134 Sam Eastman 2500 Holgate St Tacoma, WA 98402

**To construct:** An 853 SF tenant improvement to the the existing Women's Clinic Suite  
3100, located on the 3rd floor, including exam rooms and patient and  
staff support areas. MULTICARE WOMEN'S CLINIC

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 1 ; provide balance report with O.S.A. as per city approved plans.

Sincerely,

Shannon King  
Building Inspector 2  
ShannonK@PuyallupWA.gov  
(253) 840-6684