



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Oct 16, 2023 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRCCP20221569

Property Address: 4002 10TH ST SE, PUYALLUP, WA 98374;

Contractor: BRC FAMILY LLC PO BOX 731310 PUYALLUP, WA 98373-0060 GREAT
NORTHWEST EXCAVATION LLC 12203 40TH AVE TACOMA, WA 98466

To construct: Extend utilities from 10th street SE on a site for purposes of construction
2- 6 plexus as well as provide infiltration on site. COPPERBERRY
CONDOMINIUMS

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: PRFUP20231150 - Puget Paving removed the C&G and sidewalk. Rain saturated the SG and needs to dry out prior to pour. The roots and the dirt need to be removed and replaced with crushed rock. The back side is high and need to be pulled back for forms. Sidewalk was caution taped off and needs sidewalk closed signs along with sidewalk detour signs.

Corrections:

Sincerely,



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

A handwritten signature in black ink, consisting of a large, loopy initial 'J' followed by a series of vertical, wavy lines that resemble the letters 'LITTLE'. A horizontal line extends to the right from the end of the signature.

Jason Little
Engineering Tech IV
JLittle@PuyallupWA.gov
(253) 435-3636