

City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Oct 17, 2023 Inspection Result: FAILED

Permit Number: PRMH20231156

Property Address: 2504 E MAIN, PUYALLUP, WA 98372;

Contractor: UNIVERSAL REFRIGERATION PO BOX 614 AUBURN, WA 98071-0614

To construct: 1. INSTALL (3) ENERGY RECOVERY VENTILATORS.2. INSTALL (2)

ROOFTOP EXHAUST BLOWERS.3. INSTALL (1) OUTDOOR SECTION HEAT

PUMP UNIT.4. INSTALL (5) INDOOR FAN COIL UNITS.6. INSTALL

DUCTWORK, GRILLES & REGISTERS.

On this day we have inspected your construction for **Mechanical Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1. duct seal approved only
 - 2.provide city approved plans on site at time of next inspection
 - 3.provide letter from engineer of record for the relocation of equipment being outside the conditioned space
 - 4. provide letter from engineer of record specifying insulation on ductwork outside of the conditioned space
 - 5. no city approved plans where on site at time of inspection
- 2 1; provide letter from engineer of record for the relocation of equipment being outside the conditioned space
 - 2 ; provide letter from engineer of record specifying insulation on ductwork outside of the conditioned space
 - $\ensuremath{\mathtt{3}}$; complete items from previous inspection.
 - ok to cover ceiling as discussed with Todd



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684