



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Oct 20, 2023                      **Inspection Result:**     **PARTIAL PASS**

**Permit Number:** PRCCP20220189

**Property Address:** 1601 39TH AVE SE, PUYALLUP, WA 98374;

**Contractor:** CECCANTI, INC. PO BOX 39 SPANAWAY, WA 98387

**To construct:** PARKING LOTS B & C; PARKING IMPROVEMENTS: ASPHALT  
PAVING; CONCRETE PAVING & STORMWATER ~ PIERCE COLLEGE  
PARKING EXPANSION

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** Updated punchlist. See updated punchlist inspection report.  
Also see corrections.

\*Please notify inspector the day prior to work being done.

**Corrections:**

- 1 Parking Lot C Punchlist:
  - Seed and straw exposed dirt around new light poles and trenches.
- 2 Parking Lot B Punchlist:
  - Check AR seal on west center detention lids.
  - Install 6" concrete collar around 2ea. MH lids in the planter and raise to grade.
  - Install (core drill) inspection port for flow control MH w/ concrete collar.
  - Clean debris out of flow control MH & MH to the north.
  - Check hanging ladders in flow control MH & MH to the north for mounting.
  - Clean foam debris out of detention pipe.

Sincerely,



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

A handwritten signature in black ink, consisting of a large, loopy initial 'J' followed by a series of vertical, wavy lines that resemble the letters 'LITTLE'. A horizontal line extends from the right side of the signature.

Jason Little  
Engineering Tech IV  
[JLittle@PuyallupWA.gov](mailto:JLittle@PuyallupWA.gov)  
(253) 435-3636