



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Oct 20, 2023

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** PRMH20230940

**Property Address:** 1007 39TH AVE SE, PUYALLUP, WA 98374;

**Contractor:** DPR CONSTRUCTION INC 157 YESLER WAY, 2ND SEATTLE, WA 98104

**To construct:** REPLACE EXISTING RTU, LIKE -4- LIKE; IMPROVE THERMAL COMFORT & CONTROL OF STATEGIC AREAS W/IN MEDICAL CTR (3) MEDICATION RM;RETAIL PHARMACY & ADDED AREA (SEPARATE FROM MAIN SYSTEM)~ KAISER PERMENTE

On this day we have inspected your construction for **Mechanical Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** 1 ; approved test of refrigeration line set at 600 psi as noted on city approved plans sheet M211 & M212 .(rooms - B122,B127,H225)

**Corrections:**

Sincerely,

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684