



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Oct 24, 2023

Inspection Result: NOT READY

Permit Number: PRCTI20221019

Property Address: 1601 INDUSTRIAL PARK WAY, PUYALLUP, WA 98371;

Contractor: CORTI CONSTRUCTION, INC. 4024 148TH AVE NE BOTHELL, WA 98052

To construct: Tenant Improvement to build an a new office within an existing warehouse suite and revise an existing toilet partition to meet ADA standards in the existing men's restroom. Area of work: 2,755 SF No change to existing. - PROLOGIS SUITE 103

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

1. no framing, MECH, plumbing, electrical was installed at I/T room and janitors closet at time of inspection
2. provide clarification of bracing at 32" on center on demising wall on detail 16 A2.1 on city approved plans
3. ok to insulate
2. 1.THIS WAS A FRAMING INSPECTION OF I/T AND JANITOR CLOSET
- 2.provide fasteners at hard lid in to demising wall as discussed with contractor
- 3.provide electrical cover approval specific to this area
4. provide fire cover approval for this area prior to next inspection
5. provide access to drywall screws on demising wall as discussed with contractor

Sincerely,

Kevin Spruell
Building Inspector I



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

KSpruell@PuyallupWA.gov

(253) 841-5590