



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Oct 24, 2023

Inspection Result: NOT READY

Permit Number: PRCTI20230310

Property Address: 1601 INDUSTRIAL PARK WAY, PUYALLUP, WA 98371;

Contractor: ELITE MECHANICAL SERVICES LLC 8304 WOODGROVE CT SE OLYMPIA, WA 98513

To construct: ±130,912 SF, NON-STRUCTURAL INTERIOR TENANT IMPROVEMENT: WORK INCLUDES NON-STRUCTURAL DEMOLITION, NEW PARTITIONS, DOORS, AND FINISHES.

On this day we have inspected your construction for **Ceiling Grid/T-Bar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1. complete all ceiling requirements as discussed with contractor
- 2 1.complete perimeter wires as discussed with contractor
2. complete positive attachment to light fixtures as discussed with contractor
3.provide BIRC clips as discussed with contractor
4.provide electrical cover approval at time of next inspection

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590