



City of Puyallup

Fire Prevention

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Oct 30, 2023

Inspection Result: PASSED

Permit Number: PRFA20230507

Property Address: 3511 5TH ST SE, PUYALLUP, WA 98374;

Contractor: E-SQUARED SYSTEMS LLC PO BOX 731227 PUYALLUP, WA 98373

To construct: The fire alarm control panel is an outdated Silent Knight 5820XL that is being replaced with a 6820. Both annunciators are being relocated from exterior to interior locations. Install a Telguard Communicator.

On this day we have inspected your construction for **Fire Alarm Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

Sincerely,

David Drake
Building Inspector II
DDrake@PuyallupWA.gov
(253) 864-4171