



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Oct 30, 2023                      **Inspection Result:**      **PASSED**

**Permit Number:** PRCTI20230830

**Property Address:** 407 VALLEY AVE NE, PUYALLUP, WA 98372;

**Contractor:** FARRELL-MCKENNA CONSTRUCTION 17786 DES MOINES MEMORIAL  
DR BURIEN, WA 98148 (206) 241-2600

**To construct:** Interior Unit Building Renovation - Meridian Pointe Apartments  
Building 'J' Units 101/201/301

On this day we have inspected your construction for **Combination Frame And Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

1. repair leak on hot supply in kit unit 201

Sincerely,

Kevin Spruell  
Building Inspector I  
KSpruell@PuyallupWA.gov  
(253) 841-5590