



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Oct 31, 2023

Inspection Result: **FAILED**

Permit Number: E-18-0487

Property Address: 401 15TH AVE SE, PUYALLUP, WA 98372;

Contractor:

To construct: ADA RAMP AND DRIVEWAY UPGRADES ~ REPLACES E-17-0024

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: There are several issues with multiple areas. But the one area I am focused on is the garage entrance/exit off 13th.

- 2-3 areas of unsealed overcuts
- Large chips in gutter pan
- Lifted and separated sidewalk above ADA ramp due to tree.

Corrections:

Sincerely,

Jason Little



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Engineering Tech IV

JLittle@PuyallupWA.gov

(253) 435-3636