



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Oct 31, 2023

**Inspection Result:** **FAILED**

**Permit Number:** PRCTI20231087

**Property Address:** 4621 S MERIDIAN, Unit: A915, PUYALLUP, WA 98373;

**Contractor:** ORANGE CONSTRUCTION 310 N. 103rd ST SEATTLE, WA 98133--9174

**To construct:** TENANT IMPROVEMENT OF VETERINARY IN AN EXISTING SUITE. NO CHANGE OF USE OR OCCUPANCY - VALUE PET CLINIC

On this day we have inspected your construction for **Slab/Insulation Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 1 ; pending as built plumbing plan approved from mechanical engineer of record.
- 2 1 ; complete plumbing cleanout at se corner of building as discussed with contractor.

Sincerely,

Shannon King  
Building Inspector 2  
ShannonK@PuyallupWA.gov  
(253) 840-6684