



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Nov 01, 2023 **Inspection Result:** **FAILED**

Permit Number: PRMH20231183

Property Address: 1001 SHAW RD, PUYALLUP, WA 98372;

Contractor: AIR SYSTEMS ENGINEERING 3602 S PINE ST TACOMA, WA 98409-8197

To construct: Remove existing 5-ton indoor heat pump and outdoor condenser units
Furnish and install (1) new Trane 5-ton split system - ABSHER CONSTRUCTION

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1 ; provide electrical final prior to mechanical final.
- 2 ; provide access port locks as discussed with contractor
- 3 ; protect insulation at refrigeration line set from u.v. rays.
- 4 ; fix insulation on supply and return air in attic.

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org