



City of Puyallup

Fire Prevention

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Nov 07, 2023

Inspection Result: PASSED

Permit Number: PRFA20221485

Property Address: 1414 VALLEY AVE NW, PUYALLUP, WA 98371;

Contractor: FIRE CHIEF EQUIPMENT PO BOX 659 REDMOND, WA 98073

To construct: Replace like for like-Replacing 12 FFAST Air Sampling Detectors with 12 Vesda Evue Detectors

On this day we have inspected your construction for **Fire Alarm Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

Sincerely,

David Drake
Building Inspector II
DDrake@PuyallupWA.gov
(253) 864-4171