



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Nov 07, 2023 **Inspection Result:** **FAILED**

Permit Number: PRCNC20220958

Property Address: 324 S MERIDIAN, PUYALLUP, WA 98371;

Contractor: NEELEY CONSTRUCTION COMPANY 111 23RD ST SE PUYALLUP, WA
98372-4163 (253) 627-4367

To construct: 1,200SF park restroom structure renovation/ addition at City of
Puyallup's Pioneer Park

On this day we have inspected your construction for **Fire Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1. Provide Fire Extinguisher in cabinet.
2. Provide signage on cabinet.
3. Fire Extinguisher is not in a locking cabinet with a breakable front. Will this not be secured?

Sincerely,

David Drake
Building Inspector II
DDrake@PuyallupWA.gov
(253) 864-4171