



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Nov 08, 2023 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRCTI20231087

Property Address: 4621 S MERIDIAN, Unit: A915, PUYALLUP, WA 98373;

Contractor: ORANGE CONSTRUCTION 310 N. 103rd ST SEATTLE, WA 98133--9174

To construct: TENANT IMPROVEMENT OF VETERINARY IN AN EXISTING SUITE. NO
CHANGE OF USE OR OCCUPANCY - VALUE PET CLINIC

On this day we have inspected your construction for **Foundation/Rebar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1 ; approved slab pour back at plumbing trenches only.

Corrections:

- 1 ; complete vapor barrier and seal penetration of plumbing as discussed with contractor..
(slab inspection only)

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684