



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Nov 08, 2023 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRMU20221555

Property Address: 4002 10TH ST SE, PUYALLUP, WA 98374;

Contractor: BRC FAMILY LLC PO BOX 731310 PUYALLUP, WA 98373-0060

To construct: North Building of CopperBerry, R-2 Apartments 6 Plex CIVIL:
PRCCP20221569 / South building PRMU20221586 - REVISION (1) -
09/11/2023 - POURING A MAXIMUM 7' WALL IN PLACE OF 4' WALL ON
WEST SIDE OF FOUNDATION

On this day we have inspected your construction for **Sidew sewer Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: As-built was received 11/7/23. Crew backfilled last night. They bedded the pipe with crushed rock, installed bury tape, and backfilled. Pictures received today.

Corrections:

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Jason Little

Engineering Tech IV

JLittle@PuyallupWA.gov

(253) 435-3636