



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Nov 08, 2023 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRMU20221586

Property Address: 4002 10TH ST SE, PUYALLUP, WA 98374;

Contractor: BRC FAMILY LLC PO BOX 731310 PUYALLUP, WA 98373-0060

To construct: South Building of CopperBerry, R-2 Apartments 6 Plex and 600 sq ft
commercial office space: IMPACT FEE DEFERRAL CIVIL: PRCCP20221569
- REVISION (1) - 09/11/2023 - POURING 5'7" FOUNDATION WALL ON
THE WEST WALL INSTEAD OF A 4' FOUNDATION WALL

On this day we have inspected your construction for **Sidesewer Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Great NW installed the 6" sewer lateral and 2 - 6" side sewers with c/o.
They bedded the pipe with crushed rock, installed bury tape, and backfilled.
As-built received.

Corrections:

- 1 Need to install a plug in both side sewers to keep construction debris out during build.

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Jason Little
Engineering Tech IV
JLittle@PuyallupWA.gov
(253) 435-3636