



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Nov 08, 2023

Inspection Result: **PARTIAL PASS**

Permit Number: PRCTI20221019

Property Address: 1601 INDUSTRIAL PARK WAY, PUYALLUP, WA 98371;

Contractor: CORTI CONSTRUCTION, INC. 4024 148TH AVE NE BOTHELL, WA 98052

To construct: Tenant Improvement to build an a new office within an existing warehouse suite and revise an existing toilet partition to meet ADA standards in the existing men's restroom. Area of work: 2,755 SF No change to existing. - PROLOGIS SUITE 103

On this day we have inspected your construction for **Wallboard / Drywall Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1. drywall at I/T closet and janitor's closet and dismissing wall approved for taping

Corrections:

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590