



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Nov 08, 2023

**Inspection Result:** NOT READY

**Permit Number:** PRCTI20230247

**Property Address:** 733 RIVER RD, PUYALLUP, WA 98371;

**Contractor:** RAAB & SON'S 12630 SW CEMTERY RD VASHON ISLAND, WA 98070

**To construct:** TI PREVIOUS EXISTING BLDG OF DMV ~ ENTERPRISE RENT-A-CAR \*

REV (1) - 11/8/2023 - REVISED LOCATION OF ADA RAMP & STRIPPING  
TO HC STALL

On this day we have inspected your construction for **Plumbing Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 1. no lines or floor drains installed at time of inspection that go in to grease interceptor  
2. provide AS-built approval of under ground plumbing from EOR at time of slab inspection  
3. DWV under slab approved pending as-built approval from EOR
- 2 1. trench drains under slab approved inside building  
2. provide approval from engineering for outside the building
- 3 1. NO ONE ON SITE AT TIME OF INSPECTION 10:55 AM

Sincerely,

Kevin Spruell  
Building Inspector I  
[KSpruell@PuyallupWA.gov](mailto:KSpruell@PuyallupWA.gov)  
(253) 841-5590