



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Nov 09, 2023                      **Inspection Result:**     **PASSED**

**Permit Number:** PRMH20230940

**Property Address:** 1007 39TH AVE SE, PUYALLUP, WA 98374;

**Contractor:** DPR CONSTRUCTION INC 157 YESLER WAY, 2ND SEATTLE, WA 98104  
**To construct:** REPLACE EXISTING RTU, LIKE -4- LIKE; IMPROVE THERMAL COMFORT & CONTROL OF STATEGIC AREAS W/IN MEDICAL CTR (3) MEDICATION RM;RETAIL PHARMACY & ADDED AREA (SEPARATE FROM MAIN SYSTEM)~ KAISER PERMENTE

On this day we have inspected your construction for **Mechanical Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** 1 ; approved refrigeration line set test at 600 psi.

**Corrections:**

Sincerely,

Shannon King  
Building Inspector 2  
ShannonK@PuyallupWA.gov  
(253) 840-6684