



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Nov 10, 2023                      **Inspection Result:**     **PARTIAL PASS**

**Permit Number:** PRCCP20221569

**Property Address:** 4002 10TH ST SE, PUYALLUP, WA 98374;

**Contractor:** BRC FAMILY LLC PO BOX 731310 PUYALLUP, WA 98373-0060 GREAT  
NORTHWEST EXCAVATION LLC 12203 40TH AVE TACOMA, WA 98466

**To construct:** Extend utilities from 10th street SE on a site for purposes of construction  
2- 6 plexus as well as provide infiltration on site. COPPERBERRY  
CONDOMINIUMS

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** Arrived on site at 1130 am. Great NW is importing material for the building backfill and grading. There is track out per truck and getting worse as it rains. The crew has one person hand sweeping the street into the curb and the sidewalk. I asked them to clean out the curb and keep the street swept all the way to the end of the track out just south of the property line. The trucks are separating the sidewalk creating a tripping hazard. I asked the crew to add cold mix at the end of the day to fill in the missing pieces and extra wide cracks in the sidewalk. Left the site at 1230 pm. Arrive back on site @ 2pm. Great NW is finishing up. We discussed removing the back 2' section of broken sidewalk and installing spalls.

The GC will need to keep an eye on this area. If this area becomes a tripping hazard and is not maintained they will need to place cold mix. Hard surface is the only approval for ADA pedestrian access.

The streets and gutter look good. Left the site @ 1430.

**Corrections:**

Sincerely,



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

Jason Little

Engineering Tech IV

[JLittle@PuyallupWA.gov](mailto:JLittle@PuyallupWA.gov)

(253) 435-3636