



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Nov 13, 2023                      **Inspection Result:**      **PARTIAL PASS**

**Permit Number:** PRCCP20221569

**Property Address:** 4002 10TH ST SE, PUYALLUP, WA 98374;

**Contractor:** BRC FAMILY LLC PO BOX 731310 PUYALLUP, WA 98373-0060 GREAT  
NORTHWEST EXCAVATION LLC 12203 40TH AVE TACOMA, WA 98466

**To construct:** Extend utilities from 10th street SE on a site for purposes of construction  
2- 6 plexus as well as provide infiltration on site. COPPERBERRY  
CONDOMINIUMS

On this day we have inspected your construction for **Erosion And Sediment Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** Great NW installed a new concrete wash out pit. They also installed straw along the north, west, and south side of the project. Site looks good. Thank you.

GC, please keep signs up along the back portion of the sidewalk at the entrance. Also, install cold mix along the area where the sidewalk cracks expand beyond 1/2".

Thank you.

**Corrections:**

- 1 - Maintain frontage cleanliness. (Gutter pan, road way, sidewalk, etc...)
- Maintain construction entrance. (Cleanliness, track out, etc...)
- Watch runoff during heavy rain events.

Sincerely,



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

Jason Little

Engineering Tech IV

[JLittle@PuyallupWA.gov](mailto:JLittle@PuyallupWA.gov)

(253) 435-3636