



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Nov 15, 2023 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRCCP20221569

Property Address: 4002 10TH ST SE, PUYALLUP, WA 98374;

Contractor: BRC FAMILY LLC PO BOX 731310 PUYALLUP, WA 98373-0060 GREAT
NORTHWEST EXCAVATION LLC 12203 40TH AVE TACOMA, WA 98466

To construct: Extend utilities from 10th street SE on a site for purposes of construction
2- 6 plexus as well as provide infiltration on site. COPPERBERRY
CONDOMINIUMS

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Great NW is installing the sewer sample tees. They began on the NW corner of the north building. Both 6"pvc sample tees have been installed on the north building side sewer.

Note: See corrections below.

Corrections:

- 1 ALL side sewers need a plug installed in the c/o y during building construction process. Once building is ready for a final the plugs can be removed.

Sincerely,



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

A handwritten signature in black ink, consisting of a large, loopy initial 'J' followed by a series of vertical, wavy lines that resemble the letters 'LITTLE'. A horizontal line extends from the right side of the signature.

Jason Little

Engineering Tech IV

JLittle@PuyallupWA.gov

(253) 435-3636