



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Nov 15, 2023

Inspection Result: NOT READY

Permit Number: PRCTI20231176

Property Address: 418 VALLEY AVE NW, Unit: B, PUYALLUP, WA 98371;

Contractor: PACIFIC CONSTRUCTION MLTN INC. 1574 THORTON AVE SW PACIFIC
, WA

To construct: Widening one door

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

1. provide special inspection reports for fasteners as approved on city approved plans
2. provide flashing at wood that is exposed to weather as discussed with contractor
3. paint exposed rebar at tilt up wall
4. provide electrical final approval at time of next inspection

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590