



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Nov 15, 2023 **Inspection Result:** **NOT READY**

Permit Number: PRMH20231131

Property Address: 402 VALLEY AVE NW, Unit: A, PUYALLUP, WA 98371;

Contractor: MECHANICAL & CONTROL SERVICES INC 6426 18TH ST E FIFE, WA 98424

To construct: (1) RTU for office tenant improvement with ERV. New Unit heaters for warehouse. Associated ducts and diffusers ~ SUITES 101-104 - CITC SOUTH PUYALLUP * REV (1) - 11/8/2023 - UPDATE PLANS TO MATCH INSTALATION, REQUESTED BY INSPECTOR

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 3 1. provide balance report
2. provide electrical final approval
3. not ready

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590