



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Nov 15, 2023 **Inspection Result:** **FAILED**

Permit Number: E-21-0313

Property Address: 1015 39TH AVE SE, PUYALLUP, WA 98374;

Contractor: DP EXCAVATION 11410 316th st e GRAHAM, WA 98338 (253) 720-7790
DP EXCAVATION 11410 316th st e GRAHAM, WA 98338 (253) 720-7790

To construct: PARKING LOT EXPANSION W. 675 STALLS,CFG~SHB-TC PARKING EXPANSION/BENAROYA

On this day we have inspected your construction for **Erosion And Sediment Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: All trucks (contractor trucks, dump trucks, concrete trucks, ETC...) leaving the job should wash tires.

All trucks (contractor trucks, dump trucks, concrete trucks, ETC...) Should not park on site and in the mud.

Please CONSTANTLY keep the asphalt clean!

Corrections:

- 1 - Add BMP's to protect inlets, MH's, & bio-swales. (ALL swales, rock, CB's, MH's, And detention systems will need to be cleaned prior to moving forward AND acceptance!!!
 - Maintain CESCL inspections and SWPPP on site!!!
 - Zero track out. ZERO TRACK OUT!!! KEEP THE SPALLS TURNED AND CLEANED!!! Keep asphalt clean. Keep the trucks on the rock!
 - Protect slopes.

Sincerely,



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

A handwritten signature in black ink, consisting of a large loop at the top and a series of vertical, wavy lines below it, ending in a horizontal stroke.

Jason Little

Engineering Tech IV

JLittle@PuyallupWA.gov

(253) 435-3636