



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Nov 15, 2023 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRRASF20221703

Property Address: 1404 SHAW RD, PUYALLUP, WA 98372;

Contractor: MICHAEL E ALLEN CONST INC 3623 32ND AVE E TACOMA, WA 98443-1600

To construct: Building an addition of 2,905 square feet with a 2 car garage of 732 square feet.

On this day we have inspected your construction for **Underfloor Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1 ; complete ledger attachment of plate washers in contact with p.t. wood.
- 2 ; complete anchor bolts at bottom plate of pony wall and full support at pony wall to floor joist.
- 3 ; complete straps at plate break at foundation steps as per plans.
- 4 ; provide approval letter from engineer for 4"x4" installed at detail 18.(plans call for 6"x6".)
- 5 ; complete A-35 at each side of joist at cantilevered floor at rear of house as per plans.
ok to cover

Sincerely,

Shannon King



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684