



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Nov 15, 2023

Inspection Result: NOT READY

Permit Number: PRCTI20230167

Property Address: 2504 E MAIN, PUYALLUP, WA 98372;

Contractor: POE CONSTRUCTION, INC PO BOX 899 AUBURN, WA 98071-0899

To construct: Early installation of (5) design/build modular wall units - RED DOT SHOP
TI - MODULAR WALL UNITS

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1 ; inspection of modulares - 2,3,4,6, only
- 2 ; provide mechanical engineered approved plans for location of mechanical for modulares, - 2,3,4,6, as roof is rated for 3 p.s.f. (roof not approved for storage or walking as per engineering on building plans.)
- 3 ; will need to talk to plans examiner about energy code requirements of modular buildings.
not ready

Sincerely,

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

(253) 840-6684