



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Permit Review Correction Letter

Permit Application #PRFUP20231039

November 17, 2023

The City has completed the review of the above-mentioned permit submittal. All of your review comments, conditions, and redlined plans can be found on the [City's permit portal](#). Redlined plans can be found on the City's Permit Portal in the "Reviews" section under "Documents Returned for Corrections". Below please find the permit submittal review comments from your review team and re-submittal instructions. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

Re-submittal Instructions

To resubmit, you must **address all comments and upload a correction response letter** that depicts how the corrections have been addressed in your resubmittal. Avoid using "upload additional docs" unless there is NO submittal item available for your document. Please Note: If you do not resubmit as instructed your re-submittal will be rejected. If you have any questions about how to resubmit, please contact the permit center.

- 1 Log in to your permits portal and navigate to the status page for this permit under the "My Items" tab by selecting the "Upload Submittals" button under the permit number.
- 2 For each submittal item listed re-submit a new version of the submittal item by clicking the "New Version" button next to the file name of the original file submitted. DO NOT click the 'browse' button unless the document you are submitting for that submittal item is not a new version of the originally submitted document. Click 'Upload Documents' at bottom of the page.
- 3 If any re-submittal fees have been assessed, you will need to pay your resubmittal fee at the time of resubmittal. Your resubmittal will not be processed until the fee has been paid.

Corrections

Corrections to be addressed on the next set of resubmitted plans:

Engineering Review	Linda Lian	(253)841-5577	LindaL@PuyallupWA.gov
<ul style="list-style-type: none">- Provide a site specific TCP for this location. A flagger is likely necessary. If routing traffic into the turn lane the use of double cones is required [Site Plan Sheet 1 of 3]- Signalized intersection with multiple lanes. Provide a site specific TCP [Site Plan Sheet 1 of 3]- If tree trimming is necessary at this intersection provide a site specific TCP [Site Plan Sheet 1 of 3]- Valley View Dr should be wide enough to have one lane open while using flaggers. Please verify. If the road must be closed provide a detour route for review. [TCP Sheet 4 of 5]- Please resubmit the traffic control plan. <p>PLANS MUST BE SUBMITTED ON THE SAME SIZE SHEET AS THE ORIGINAL, THE SAME ORIENTATION AND ALL NEW ADDITIONAL SHEETS MUST BE ADDED TO THE END OF THE DOCUMENT</p> <ul style="list-style-type: none">- Provide a detour route for full closure of this road. [TCP Sheet 5 of 17]- Provide a detour route for full closure of this road. [TCP Sheet 4 of 17]- A flagger must control east bound 7th Ave SE traffic [TCP Page 2 of 17]- The following comment refers to the site plan: The new permit system requires that the marked up site plan be also be resubmitted when there are outstanding comments that need to be addressed. The city reviewer is not able to resolve outstanding comments or add any additional comments. Please resubmit the site plan. [TCP Sheet 5 of 17]- Remove this comment about shifting cones [TCP Page 5 of 7]- Remove this comment about road closure [TCP Page 5 of 7]- Remove this comment about road closure [TCP Page 4 of 7]- Remove this comment about shifting cones [TCP Page 4 of 7]- In order for flaggers to control E Pioneer properly the outside lane in each direction shall be closed prior to the intersection. Submit a new TCP showing the lane closure and taper [TCP Page 2 of 7]- Show on the TCP how traffic will be prevented from turning south onto 25th St SE. Signs will not prevent all drivers from making this movement.			

Conditions

The items listed in the table below are conditions of the permit that do not need to be addressed on the next resubmittal of plans but will need to be fulfilled at some point in the permit review process. The "Condition Category" indicates the approximate phase of the permit process by which the condition must be fulfilled in order for the City to continue processing this permit. "Condition Status" if "Open" means that the condition has not been fulfilled, if "Resolved" means the condition has been fulfilled successfully. For some conditions that require submittal of a document to the City, those documents can be submitted via the Conditions Section of the [City's permit portal](#).

Condition Category	Condition	Department	Condition Status
--------------------	-----------	------------	------------------

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center
(253) 864-4165 option 1
permitcenter@puyallupwa.gov