



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Nov 28, 2023

Inspection Result: NOT READY

Permit Number: PRCTI20230247

Property Address: 733 RIVER RD, PUYALLUP, WA 98371;

Contractor: RAAB & SON'S 12630 SW CEMTERY RD VASHON ISLAND, WA 98070

To construct: TI PREVIOUS EXISTING BLDG OF DMV ~ ENTERPRISE RENT-A-CAR *

REV (1) - 11/8/2023 - REVISED LOCATION OF ADA RAMP & STRIPPING
TO HC STALL

On this day we have inspected your construction for **Combination Frame And Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1. complete all requirements for framing inspection as discussed with contractor
2, not ready
- 2 1.provide fire blocking at ceiling in bathroom as discussed with contractor
2. complete duct work on mech system
3.complete duct seal
4. remove insulation from ducts to verify duct seal as discussed with contractor
5. provide clarification from MECH engineer of record on duct supports from ceiling to include seismic restraint
6.provide fire cover approval at time of next framing inspection
7. plumbing approved
8.due not insulate

Sincerely,

Kevin Spruell



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Building Inspector I

KSpruell@PuyallupWA.gov

(253) 841-5590