



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Nov 30, 2023                      **Inspection Result:**     **NOT READY**

**Permit Number:** PRPF20230347

**Property Address:** 2315 INTER AVE, PUYALLUP, WA 98372;

**Contractor:** WESTMARK CONSTRUCTION, INC 6102 N 9TH ST #100 TACOMA, WA 98406

**To construct:** Construct 4,987 SF pre-fabricated metal building warehouse; SEE PRMH20230349/MECH

On this day we have inspected your construction for **Footing/Setback Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1
- 2 1. provide special inspection approval for bar placement  
2.provide geotech reports for sub grades at footings from geotech of record  
3.provide detailed drawings from EOR for corner footing being used that are not on the plans  
4. complete F5 footings as approved on city approved  
5.due not pour  
6. not ready

Sincerely,

Kevin Spruell  
Building Inspector I  
KSpruell@PuyallupWA.gov  
(253) 841-5590



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)