



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Nov 30, 2023

Inspection Result: **FAILED**

Permit Number: PRCTI20230247

Property Address: 733 RIVER RD, PUYALLUP, WA 98371;

Contractor: RAAB & SON'S 12630 SW CEMTERY RD VASHON ISLAND, WA 98070

To construct: TI PREVIOUS EXISTING BLDG OF DMV ~ ENTERPRISE RENT-A-CAR *
REV (1) - 11/8/2023 - REVISED LOCATION OF ADA RAMP & STRIPPING
TO HC STALL

On this day we have inspected your construction for **Energy (Insulation) Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1. complete insulation at corners as discussed with contractor
2. complete insulation at hot water lines as discussed with contractor
3. complete duct work above bathrooms as discussed with contractor

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590