



CITY OF PUYALLUP
Development & Permitting Services
 333 S. Meridian, Puyallup, WA 98371
 (253) 864-4165
www.cityofpuyallup.org

Permit No:
 PRFS20231650

FIRE SPRINKLERS

Puyallup, WA

| | | |
|----------------------------|---|------------------------------------|
| Job Address | Address: 201 W MAIN, PUYALLUP, WA 98371 Parcel # 7940100244 | ISSUED December 01, 2023 |
| Owner | COMMUNITY HEALTH CARE 1148 BROADWAY STE 100 TACOMA, WA 98402 | |
| Applicant | Archer Construction Inc S 206th St Kent, WA 98032 (206) 571-6612 permits@archerconstruction.com | |
| Contractor | ARCHER CONSTRUCTION 7855 S 206TH ST KENT, WA 98032 WA L&I #: | |
| Description of Work | Modify existing fire sprinkler system to accommodate new walls and ceilings starting work near top of existing wet sprinkler riser. Also reroute all main piping so that it runs along walls or beams and reroute branch piping to be up in the joist spaces. | |
| Permit Types | Fire Sprinklers | |
| Expiration Date: | May 29, 2024 | |
| Total ESU's | | |

Building Components:

| Quantity | Units | Description |
|----------|-------|---|
| 533 | HEADS | Automatic Fire-Sprinkler System, Alteration |
| | | Total Value of Work: \$0.00 |

Standard Conditions:

1. • Provide plans and permit on site for inspection.
- Cover and final inspections are required.
- Fire watch is required when sprinkler system is out of service in existing buildings.
- Contractor required at all inspections.
- Hydro test will be required on all new and existing buildings. Appointment required.
- Hydro test, two inspections will be required 2hrs apart. Call to schedule times. Am/pm is not guaranteed without appointment.
- Fire pumps will be required to be tested and witnessed by inspector.
- Tool kit required at time of final.
- NFPA placards required.
- In existing buildings all upright fire sprinklers to remain, do not remove.

- In existing buildings all required service and maintenance to be updated prior to inspection.
- Due to unforeseeable construction design, all head locations to be field verified for compliance.

Schedule your inspection online through the city of puyallup online permit system. This is a request for inspection only. A date and time will be selected by Inspector depending on availability. Email morning of inspection between 7am – 8am for scheduled date and time. Fire Inspections are Monday – Thursday there will be no inspections on Fridays. For larger system please make an appointment prior to scheduling first.

David Drake ddrake@puyallupwa.gov

Permit is valid 180 days from date of issuance. Permit validity is subject to all adhering to all applicable codes, ordinances and standards, and conditions of this permit.

I certify that I am the owner of this property or the owner's authorized agent, including an appropriately licensed contractor. I have read and examined this application and furnished true and correct information. I will comply with all provisions of law and ordinances governing this type of construction work, whether specific herein or not. By submitting this application, I give the jurisdiction permission to enter the property to perform inspections. The granting of this permit does not presume or give authority to violate or cancel the provisions of any other state or local law regulating construction or the performance of construction. I understand that failure to comply with the above may result in revocation of the permit.

Applicant:
Archer Construction Inc