



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Dec 01, 2023

Inspection Result: **FAILED WITH FEE**

Permit Number: PRCTI20230247

Property Address: 733 RIVER RD, PUYALLUP, WA 98371;

Contractor: RAAB & SON'S 12630 SW CEMTERY RD VASHON ISLAND, WA 98070

To construct: TI PREVIOUS EXISTING BLDG OF DMV ~ ENTERPRISE RENT-A-CAR *

REV (1) - 11/8/2023 - REVISED LOCATION OF ADA RAMP & STRIPPING
TO HC STALL

On this day we have inspected your construction for **Energy (Insulation) Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1. complete insulation at corners as discussed with contractor
2. complete insulation at hot water lines as discussed with contractor
3. complete duct work above bathrooms as discussed with contractor
- 2 1. complete items from previous list
2. pay 180.00 reinspection fee prior to scheduling next inspection

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590