



City of Puyallup
Building Division
333 S. Meridian, Puyallup, WA 98371
(253) 864-4165
www.cityofpuyallup.org

Permit Revision Review Correction Letter

Permit Application # PRCTI20221714

December 04, 2023

The City has completed the review of the above-mentioned permit revision submittal REV (1) - 11/20/2023 - REVISE SIDE SEWER CONNECTION LOCATION. All your review comments, conditions, and redlined plans can be found on the [City's permit portal](#). Redlined plans can be found on the City's Permit Portal in the "Reviews" section under "Documents Returned for Corrections". Below please find the permit submittal review comments from your review team and re-submittal instructions. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

Re-submittal to an Issued Permit Instructions

To resubmit, you must address all comments and complete and submit the [resubmittal form](#) and a letter of transmittal. If you have any questions about how to resubmit, please contact the permit center.

- 1 Email your revision resubmittal with all the corrections to the Permit Center at permitcenter@puyallupwa.gov and we will upload your documents for you. Once we have uploaded the revised revision documents, we will send you an email to pay the resubmittal fee. **The fee must be paid prior to the revision moving forward.**

Corrections

Corrections to be addressed on the next set of resubmitted plans:

Building Review	Janelle Montgomery	(253)770-3328	JMontgomery@PuyallupWA.gov
<p>- Provide revised sewer connection from engineer of record. Clarify how it will tie into existing clearly not with X. Where will CO be located with ones being eliminated. Clarify how many fixtures will be on the 3" drain. Page P2.01</p> <p>- Clarify why reducing to 2" at this point between 3" line. Page P2.01</p>			
Engineering Review	Linda Lian	(253)841-5577	LindaL@PuyallupWA.gov

- 1) engineering needs the seal 2) line is detailed very close to the common bearing wall, please verify clearance from the bearing angle of influence. - Provide the city with a CCTV of the existing sewer lateral in order to determine if that lateral does not need is viable for the proposed use. [Plumbing Plan P2.01 Rev(1)(1)*]			

Conditions

The items listed in the table below are conditions of the permit that do not need to be addressed on the next resubmittal of plans but will need to be fulfilled at some point in the permit review process. The “Condition Category” indicates the approximate phase of the permit process by which the condition must be fulfilled for the City to continue processing this permit. “Condition Status” if “Open” means that the condition has not been fulfilled, if “Resolved” means the condition has been fulfilled successfully. For some conditions that require submittal of a document to the City, those documents can be submitted via the Conditions Section of the [City’s permit portal](#).

Condition Category	Condition	Department	Condition Status
Prior to Issuance	The building permit shall not be issued until the frontage improvement design has been approved by the City. See Civil Permit PRCCP20221725.	Engineering Division	Resolved
Prior to Issuance	Prior to issuance a utility permit must be issued to install the required sewer lateral sampling tee can be inconjunction with the installation of the RPBA. See Civil Permit PRCCP20221725. LL 01/17/2023	Engineering Division	Resolved
Prior to Issuance	Prior to issuance a utility permit must be issued to install the required RPBA can be inconjunction with the installation of the sewer sampling tee. See Civil Permit PRCCP20221725. LL 01/17/2023	Engineering Division	Resolved
Prior to Occupancy	All work associated with the installation of the frontage improvements and the RPBA must be complete and a final approval granted. See Civil Permit PRCCP20221725. LL 11/09/2022	Engineering Division	Open

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center
 (253) 864-4165 option 1
permitcenter@puyallupwa.gov