

City of Puyallup **Engineering Division** 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

## **INSPECTION REPORT**

Date of Inspection:	Dec 04, 2023	Inspection Result:	FAILED
Permit Number: Property Address:	PRCCP20221569 4002 10TH ST SE, PUYAL	LUP, WA 98374;	
Contractor:	BRC FAMILY LLC PO BO		
To construct:	Extend utilities from 10th street SE on a site for purposes of construction		
	2- 6 plexus as well as provide infiltration on site. COPPERBERRY CONDOMINIUMS		

On this day we have inspected your construction for **Erosion And Sediment Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

## Comments: Site walk:

- Stabilize with straw bare areas worked for sewer and storm.
- Delineate west side of north building. This area is soft. No fork lift and minimal foot traffic.
- Remove wood from gutter pan during heavy rain. Only use when deliveries to project.
- Remove nails in the street.

## Corrections:


- 1 Maintain frontage cleanliness. (Gutter pan, road way, sidewalk, etc...)
  - Maintain construction entrance. (Cleanliness, track out, etc...)
  - Watch runoff during heavy rain events.

Sincerely,

## City of Puyallup



**Engineering Division** 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org



Jason Little Engineering Tech IV JLittle@PuyallupWA.gov (253) 435-3636