



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Dec 04, 2023 **Inspection Result:** **NOT READY**

Permit Number: PRPF20230347

Property Address: 2315 INTER AVE, PUYALLUP, WA 98372;

Contractor: WESTMARK CONSTRUCTION, INC 6102 N 9TH ST #100 TACOMA, WA 98406

To construct: Construct 4,987 SF pre-fabricated metal building warehouse; SEE PRMH20230349/MECH

On this day we have inspected your construction for **Footing/Setback Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1
- 2
 1. provide special inspection approval for bar placement
 2. provide geotech reports for sub grades at footings from geotech of record
 3. provide detailed drawings from EOR for corner footing being used that are not on the plans
 4. complete F5 footings as approved on city approved
 5. due not pour
 6. not ready
- 3
 1. provide geotech report that supports all areas that support footing, referencing min soil Bearing as on city approved plans as discussed with contractor
 2. provide approval letter from engineer of record for corner pads used that where not on city approved plans
 3. provide letter from engineer of record on the 18" footing depth approval on the F5 footing that was poured on site (24" was what was approved on city approved plan)

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Kevin Spruell

Building Inspector I

KSpruell@PuyallupWA.gov

(253) 841-5590