



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Dec 11, 2023

Inspection Result: **FAILED**

Permit Number: PRCCP20221725

Property Address: 201 W MAIN, PUYALLUP, WA 98371;

Contractor: ALDRICH & ASSOCIATES INC. 810 240TH ST SE BOTHELL, WA 98021

To construct: New electrical trenching- Install new sidewalk- Grading for new enclosed stair - COMMUNITY HEALTHCARE - CANNERY BLDG
PRCTI20221698STOP WORK ORDER generated on 08/01/2023 by username 'Jeff Hill'.STOP WORK ORDER removed on 09/27/2023 by username 'Jeff Hill'.

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Archer is excavating along side of the west building. No sidewalk closure, excavator is blocking the sidewalk, no cb socks in the catch basin. They covered the spoils with plastic and fenced off the hole.

Corrections:

- 1 When blocking the sidewalk the contractor must have sidewalk closed ahead, sidewalk closed , and a pedestrian detour set up.
- 2 install catch basin socks along the frontage.

Sincerely,

Jeff Hill

Engineering Tech IV

Jhill@PuyallupWA.gov

(253) 841-5424



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org