



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Dec 15, 2023                      **Inspection Result:**      **PARTIAL PASS**

**Permit Number:** PRCCP20221569

**Property Address:** 4002 10TH ST SE, PUYALLUP, WA 98374;

**Contractor:** BRC FAMILY LLC PO BOX 731310 PUYALLUP, WA 98373-0060 GREAT  
NORTHWEST EXCAVATION LLC 12203 40TH AVE TACOMA, WA 98466

**To construct:** Extend utilities from 10th street SE on a site for purposes of construction  
2- 6 plexus as well as provide infiltration on site. COPPERBERRY  
CONDOMINIUMS

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** Please remove wood from gutter. Only use it here on delivery days.  
Sweep sidewalk and street.

**Corrections:**

- 1 ALL side sewers need a plug installed in the c/o y during building construction process. Once building is ready for a final the plugs can be removed.

Sincerely,



City of Puyallup

---

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

A handwritten signature in black ink, consisting of a large loop at the top and a series of vertical, wavy lines below it, ending in a horizontal stroke.

Jason Little

Engineering Tech IV

[JLittle@PuyallupWA.gov](mailto:JLittle@PuyallupWA.gov)

(253) 435-3636